



कार्यालय नगर निगम ग्रेटर, जयपुर

(पण्डित दीनदयाल उपाध्याय भवन, लालकोठी, टॉक रोड जयपुर-302015, राजस्थान)

क्रमांक :- एफ.31()मु.स्वा.अधि./ननिज/2025/60

दिनांक :- 20-5-25

SAFE DRINKING WATER AND SANITARY CONDITIONS CERTIFICATE

It is certified that an inspection team headed by **Dr. Rashmi Kankaria, Chief Health Officer** from Nagar Nigam Greater, Jaipur inspected the **WARREN ACADEMY SCHOOL, Saini Colony Ext. Kartarpura, Jaipur** on 30-04-2025 and on the basis of the Water Test Report (Attached) bearing no 9437 dated 02-12-2024 certified that the **WARREN ACADEMY SCHOOL** has safe drinking water facilities for the students and members of staff of the institution, School is maintaining the hygienic sanitation condition in the building & the campus as per the norms prescribed by the Central/State/U.T.Govt.

The Certificate is valid upto 31 March. 2026.

(Dr. Rashmi Kankaria)
Chief Health Officer
Nagar Nigam Greater Jaipur

To,

The Principal,
WARREN ACADEMY SCHOOL
Saini Colony Ext. Kartarpura, Jaipur

D/Dr.Rashmi Kakariya/All Letter



Signature valid

Digitally signed by Rashmi Kankaria
Designation: Chief Health Officer
Date: 2025.05.20 17:16:30 IST
Reason: Approved

35

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2025-2026/ 5132

Date: 13/02/2026

To,

Warren Academy School
 Saini Colony Ext. . Kartarpura
 Jaipur

The Sample was not Collected
 by this Laboratory

Not Valid for water
 quality Legal uses

Your Letter No-6821 dated 10/02/2026
 Date of Receipt 10/02/2026

Particulars			RO Water
	<i>value as per I.S.:10500/2012</i>		Warren Academy School
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			10/02 /2026
Date of Examination			10/02 /2026
Lab. Sample No.			P-190
1. pH	6.5-8.5	6.5-8.5	6.83
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O
5. Total Alkalinity(as CaCo3) mg/l	200	600	20
6. Total Hardness (as CaCo3) mg/l	200	600	16
7. Calcium (as Ca) mg/l	75	200	4
8. Magnesium (as Mg) mg/l	30	100	2
9. Chloride (as Cl-) mg/l	250	1000	16
10. Nitrates (as NO3-) mg/l	45	45	4
11.Sulphate(as So4-2)mg/l	200	400	2
12. Total Dissolved Solids mg/l	500	2000	79
13.Fluoride mg/l	1.00	1.5	0.05
14.Iron mg/l	1.0	No Relaxation	Nil
15.Arsenic mg/l	0.01	No Relaxation	Nil

Remark- 1. All chemical parameters except pH are in mg/l
 2. Tested Results Relate only to The Samples send by you

Sent
 Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur

No: Lab/ Sup.Chem. (HM) / Jaipur (City) /2025-2026/
 Copy to:- 1.The Chief Chemist, PHED Raj. Jaipur

Date:
 Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur